Commonwealth of Kentucky Division for Air Quality

PERMIT APPLICATION SUMMARY FORM

Completed by: Esmail Hassanpour

<u>GENERAL INFORMATION:</u>		
Name:	Conopco. Inc	
Address:	1901 Ragu Drive, Owensboro, Kentucky 40511	
Date application received:	October 9, 2003	
SIC/Source description:	2033	
AFS #:	21-059-00047	
Application log number:	56058	
Permit number:	F-03-031	
APPLICATION TYPE/PERMIT AC	<u>TIVITY</u> :	
[x] Initial issuance	[] General permit	
[] Permit modification	[x] Conditional major	
Administrative	[] Title V	
Minor	[] Synthetic minor	
_ Significant	[x] Operating	
[] Permit renewal	[] Construction/operating	
COMPLIANCE SUMMARY:		
[] Source is out of complian	nce [] Compliance schedule included	
[x] Compliance certification	n signed	
APPLICATION REQUIREMENT L	IST:	
[]NSR	NSPS [x] SIP	
[] PSD	NESHAPS [] Other	
[] Netted out of PSD/NSR		
MISCELLANEOUS:		
Acid rain source		
Source subject to 112(r)		
Source applied for federa	ally enforceable emissions cap	
	or alternative operating scenarios	
[] Source subject to a MAC	'T standard	
[] Source requested case-by	y-case 112(g) or (j) determination	
[] Application proposes nev	w control technology	
[x] Certified by responsible	e official	
[] Diagrams or drawings in		
[] Confidential business info	formation (CBI) submitted in application	
[] Pollution Prevention Mea	asures	
[] Area is non-attainment (l	ist pollutants):	

Pollutant	Actual (tpy)	Potential (tpy)
PM10/PT	6.84	6.84
SO_2	89.99	89.99
NOx	82.1	82.1
СО	54.01	54.01
VOC	3.82	3.82

Source Process Description:

A Title V draft permit was issued by Division on September 20, 2003 and advertised on October 8, 2003. However, the comments received from permittee on October 3, 2003, requested the Division to withdraw the Title V draft (V-03-036) and reconsider the application for to Federally Enforceable Conditional Major permit. The letter is indicating that source will to limit source wide SO2 emission to 90 tons/yr and operate pursuant to a Federally Enforceable Conditional Major requirement

INTIAL ISSUANCE:

A Title V operating permit application was received from Conopco, Inc. on July 3, 2001. The application was deemed administratively complete on September 11, 2003. The facility currently operates under permit number O-88-087. The facility is equipped with two boilers, and processes tomato paste, spices and other food ingredients to make pasta sauces.

The Cleaver Brooks boiler emission unit 1 (EU), and the Nebraska boiler emission unit 2 burns natural gas and uses # 2 oil as a back up fuel. The boilers are rated 54 mmBTU/hr, and 73.1 mmBTU/hr respectively.

EMISSION AND OPERATING CAPS DESCRIPTION

To preclude Regulation 401 KAR 52:020, the source has taken a federally enforceable limit on the oil to be burned at Emission Points 01 and 02. The annual limit of 2717913 gallon/yr of oil burned shall not be exceeded, and hours of operation for # 2 fuel oil shall be 114 days or 2736 hrs/yr. The source wide sulfur dioxide (SO2) emission shall not exceed 90 tons/yr.

OPERATIONAL FLEXIBILITY: